



NOTES:

1. Customer must contact the City for proper conduit location on pole.
2. City will determine pole height to terminate conduit.
3. Standoff conduits a minimum of 1 5/8".
4. Cable to be pulled after entire run of conduits is installed.

Fig. 8